



# Certificate of Compliance

|                                  |                                                                                    |                         |                                        |
|----------------------------------|------------------------------------------------------------------------------------|-------------------------|----------------------------------------|
| <b>Certificate:</b>              | 80246844                                                                           | <b>Master Contract:</b> | 305607                                 |
| <b>Project:</b>                  | 80246844                                                                           | <b>Date Issued:</b>     | 2026-07-27                             |
| <b>Issued to:</b>                | Solar Mounts LLC<br>300 Woolley Drive<br>Marshall, Michigan 49068<br>United States | <b>Issued by:</b>       | Michael Hoffnagle<br>Michael Hoffnagle |
| <b>Attention:</b> Terence Parker |                                                                                    |                         |                                        |

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C', 'US' and ▲*



## PRODUCTS

**Class 5313 91 POWER SUPPLIESPHOTOVOLTAICS-Racking Equipment - Mounting/Clamping/Retention Devices-  
Component-Cert to CSA Stds**  
**Class 5313 92 POWER SUPPLIESPHOTOVOLTAICS-Racking Equipment - Mounting/Clamping/Retention Devices -  
Component - Cert to US Stds**

### **PV Racking Component for bonding of PV modules**

|           |
|-----------|
| Model(s)  |
| Mid Clamp |

The component listed is designed to provide bonding/grounding for PV modules mounted on the racking system. The modules are bonded to the racking system with anodization-piercing top-down clamps. The grounding of the system is intended to comply with the latest edition of the National Electrical Code, to include NEC 250 & 690. Local codes compliance is required, in addition to national codes. All grounding/bonding connections are to be torqued in accordance with the Installation Manual and the settings used during the certification testing for the current edition of the project report.



**Certificate:** 80246844

**Master Contract:** 305607

**Project:** 80246844

**Date Issued:** 2026-07-27

Racking system component has been evaluated for bonding/grounding only.

**APPLICABLE REQUIREMENTS**

| Standards Used                                                                               | Description                                                                                                                                                    |
|----------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|
| CSA TIL NO. A-40                                                                             | CSA TIL NO. A-40 - PV Module and Panel Racking Mounting System and Accessories                                                                                 |
| ANSI/UL 2703:2015 - First Edition - Including revisions through and including April 28, 2026 | UL Standard for Safety Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels |



**Certificate:** 80246844

**Project:** 80246844

**Master Contract:** 305607

**Date Issued:** 2026-07-27

Notes:

Products certified under Class(es) C531391, C531392 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)





## *Supplement to Certificate of Compliance*

**Certificate:** 80246844

**Master Contract:** 305607

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

| <b>Project</b> | <b>Date</b> | <b>Description</b>                                                                                                                   |
|----------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------|
| 80246844       | 2026-07-27  | Component level certification for bonding clamp. Evaluation and testing for bonding only.<br>Bonding Conductor and Humidity Testing. |